

SITE SPECIFIC NOTES

**REMOVAL NOTES** 

V1-HH1

REMOVE UG TPX, L=110'

AT HH1 REMOVE EXISTING SECONDARY HH

HH1-P1 REMOVE UG SEC TPX, L=40'

## **INSTALLATION NOTES**

AT V1 GRID# 225312-167067

REMOVE EXISTING 25KVA PM XFMR INSTALL (1) NEW 50 KVA PM XFMR INSTALL GRID# 225612-167067 AT P1 GRID# 225614-167077

REMOVE EXISTING SERVICE POLE

INSTALL (1) RUN OF 350 UG TPX, L=140'

\* \* \* CUSTOMER TO PROVIDE 3' X 3' WORK PIT \* \* \*

INSTALL (1) 17X30 FIBERGLASS HH PER STD. 6050.2000

INSTALL (3) 6-POS. FARGOS

**V1 - LOT 1W** 

INSTALL (1) RUN OF 4/0 UG TPX. L=80' INSTALL (1) 3" CONDUIT STUB-OUT

HH2-LOT 2W

INSTALL (1) RUN OF 4/0 UG TPX, L=10' INSTALL (1) 3" CONDUIT STUB-OUT

**V1 - LOT 3W** 

INSTALL (1) RUN OF 4/0 UG TPX, L=180' INSTALL (1) 3" CONDUIT STUB-OUT

HH2 - LOT 1E

INSTALL (1) RUN OF 4/0 UG TPX, L=60' INSTALL (1) 3" CONDUIT STUB-OUT

HH2 - LOT 2E

INSTALL (1) RUN OF 4/0 UG TPX, L=10' INSTALL (1) 3" CONDUIT STUB-OUT

**APPROVED** JAN. 28, 2016

T. PHAN

**PUBLIC WORKS** 

DEPARTMENT

# 1. THE CUSTOMER IS RESPONSIBLE FOR PROVIDING ALL TRENCHING, PER THE TRENCH

POWER GENERAL NOTES - PLAT PROJECT

PROFILE, AND ALL EXCAVATIONS AT THE TRANSFORMER/HANDHOLE VAULT SITES SUCH THAT PSE FACILITIES WILL MATCH FINAL GRADE. VAULT HOLES WILL HAVE STABLE LEVEL BOTTOMS. CUSTOMER WILL PROVIDE 6" OF CRUSHED ROCK FOR VAULT BEDDING. ALL TRENCHES WILL HAVE 6" OF WASHED SAND COVER AND 4" BEDDING FOR ALL CONDUITS. THE CUSTOMER WILL PROVIDE SELECT BACKFILL, IF REQUIRED, AND COMPACTION AS NECESSARY. THE CUSTOMER IS RESPONSIBLE FOR DISPOSAL OF ALL NATIVE SPOILS <u>NOT</u> SUITABLE FOR USE AS BACKFILL. ALL TRENCHES MAY BE JOINT WITH GAS, TELEPHONE AND TV CABLE.

2. ALL CABLES/CONDUITS TO BE INSTALLED IN CUSTOMER'S TRENCH AT THE DEPTH INDICATED IN TRENCH DETAIL (DEPENDENT UPON SIZE OF CONDUIT BEING INSTALLED TO MEET MIN 36" OF COVER). INSTALL CABLE ID TAGS AT EACH END OF THE PRIMARY CABLES PER THE CIRCUIT ONE-LINE DIAGRAM.

3. UNLESS OTHERWISE SPECIFIED BY MUNICIPALITIES, INSTALL PVC (DB-120) ROAD CROSSINGS AS INDICATED ON THE CROSSINGS CONDUIT TABLE & AS SHOWN ON WORK SKETCH. CROSSINGS SHALL BE INSTALLED BY CUSTOMER/DEVELOPER PER PUGET SOUND ENERGY STANDARDS.

4. AT SYMBOL: — — — — INSTALL UNDERGROUND PRIMARY CABLES IN CONDUIT. CABLE LENGTH AND CONDUIT SIZE AS INDICATED ON PRIMARY CABLE & CONDUIT TABLE.

5. AT SYMBOL: — — — — INSTALL 600 VOLT UG SECONDARY CABLES IN CONDUIT. CABLE/CONDUIT SIZE AND LENGTH AS INDICATED ON SECONDARY CABLE & CONDUIT TABLE.

6. AT SYMBOL: INSTALL MINI-PAD HANDHOLE & PADMOUNT TRANSFORMER. ADDITIONAL EQUIPMENT AS INDICATED ON VAULT TABLE.

7. AT SYMBOL: INSTALL SECONDARY PEDESTAL/HANDHOLE W/ (3) MULTI-CONNECTORS. SIZE AS INDICATED ON SECONDARY HH/PEDESTAL TABLE. (EXCAVATION: 3' SQ.)

8. AT SYMBOL: UNSTALL JUNCTION BOX HANDHOLE. ADDITIONAL EQUIPMENT AS INDICATED ON VAULT TABLE.

9. AT SYMBOL: INSTALL SECONDARY CABLE & CONDUIT STUB-OUT.

10. AT SYMBOL: \*\* INSTALL STREET LIGHTING STANDARD. SIZE AND TYPE OF STANDARD/LUMINARIE AS INDICATED ON STREET LIGHTING TABLE. (CUSTOMER TO EXCAVATE & INSTALL CORRUGATED STREET LIGHT TUBES FOR PLACEMENT OF THE STREET LIGHT STANDARDS.)

11. INCLEMENT WEATHER CONDITIONS MAY CAUSE DELAYS IN CONSTRUCTION TIMES AND DATES.

#### **EROSION & SEDIMENT CONTROL REQUIREMENTS**

EROSION & SEDIMENT CONTROL SHALL BE PER PSE STANDARD PRACTICE 0150.3200 TECHNIQUES FOR TEMPORARY EROSION & SEDIMENT CONTROL & ANY ADDITIONAL LOCAL JURISDICTION REQUIREMENTS. (LOCAL JURISDICTIONS MAY HAVE ADDITIONAL REQUIREMENTS INCLUDING NOTES DETAILING WHERE EROSION OR SEDIMENT CONTROL STRUCTURES ARE TO BE INSTALLED, CROSS SECTION DETAILS OF THE TYPICAL EROSION STRUCTURES, & SPECIAL REQUIREMENTS FOR WORK IN SENSITIVE AREAS.)


Vicinity Map

TB PG 536 G-1


# DB120 PVC -STUBOUT DETAIL

Not to scale


Backfill for In Conduit - The backfill layer shall be soil that is free from construction debris, glass, sharp rocks, frozen clods, and rocks larger than 8 " in diameter.



TRENCH DETAIL Electric Service Cable in Conduit (NTS)



TRANSFORMER REMOVAL Removed at site: Grid Number: 225612-167067 kVA Rating: 25 Foreman to redline the following information Company ID#: Primary phase connected to: Tested Secondary Voltage



SINGLE PHASE SECONDARY HANDHOLE Not to scale 6050.2000

## AT V1

Sq. Footage: N/A Panel Size: N/A Heat Type: N/A Est. Demand: 70 LRC: 115 A % V. Drop: 2.5% % Flicker: 1.3% Svc Size: N/A Svc Length: N/A

## V1 - HH2

Sq. Footage: N/A Panel Size: N/A Heat Type: N/A Est. Demand: 20 KW LRC: 115 A % V. Drop: 3.2% % Flicker: 2.2% Svc Size: 350 UG TPX Svc Length: 140'

### HH2 - LOT 2E Sq. Footage: 7204 Panel Size: 200 A Heat Type: GAS Est. Demand: 10 KW LRC: 115 A % V. Drop: 3.4% % Flicker: 2.8% Svc Size: 4/0 UG TPX Svc Length: 60'

## **V1 - LOT 1W**

Sq. Footage: 6981 Panel Size: 200 A Heat Type: GAS Est. Demand: 10 KW LRC: 115 A % V. Drop: 2.8% % Flicker: 2.1% Svc Size: 4/0 UG TPX Svc Length: 80'

## HH2 - LOT 2W


Sq. Footage: 6991 Panel Size: 200 A Heat Type: GAS Est. Demand: 10 KW LRC: 115 A % V. Drop: 3.3% % Flicker: 2.5% Svc Size: 4/0 UG TPX Svc Length: 30'

## V1 - LOT 3W

Sq. Footage: 6981 Panel Size: 200 A Heat Type: GAS Est. Demand: 10 KW LRC: 115 A % V. Drop: 3.3% % Flicker: 3.2% Svc Size: 4/0 UG TPX Svc Length: 200'

## HH2 - LOT 1E

Sq. Footage: 7200 Panel Size: 200 A Heat Type: GAS Est. Demand: 10 KW LRC: 115 A % V. Drop: 3.6% % Flicker: 3.2% Svc Size: 4/0 UG TPX Svc Length: 110'



FOREMAN (CHECK BOX WHEN COMPLETED)

CALL (800) 424-5555 **2 BUSINESS DAYS BEFORE YOU DIG** <u>Developer</u> THIS SKETCH NOT TO BE RELIED UPON FOR EXACT LOCATION OF EXISTING FACILITIE "Locates Required "Outages Required REAL ESTATE/EASEMENT "Flagging Required" EASEMENT KIRKLAND FUNCTION CONTACT PHONE NO DATE PROJECT MGR M. BOSSHARDT (425) 457-9295 1/7/16 ENGR - POWER M. BOSSHARDT (425) 457-9295 1/7/16 REV# DATE BY DESCRIPTION ENGR - GAS N/A N/A N/A mer Sect | Gas Wk Ctr | POWER WK CTR RAWN BY A. SPRENGER (425) 505-3988 N/A N/A CSPFEPM CHECKED BY /4 SEC OP MAP PLAT MAP PPROVED BY FOREMAN #1 -MAP NO (POWER) OH CKT MAP UG CKT MAP CIRCUIT NO FOREMAN #2 2605E132 2605E132 2605E132 ROS-21 APPING JOINT FACILITIES ARRANGEMENTS N/A CONTAC N/A PHONE# N/A

PUGET **► SOUND DESIGNED BY** PSE

MERIT HOMES - EOS 5 LOT PLAT

12618 NE 105th PL, KIRKLAND, WA 98033

MAOP N/A Elect Order Gas Order 105080153 N/A SCALE N/A

## STANDARD EASEMENT PROVISION An easement is hereby reserved for and conveyed to Puget Sound Energy,

Inc., Telephone Co., Television Cable Co., and their respective successors and assigns under and upon the private street(s), if any, and the exterior ten (10) feet of all lots, tracts and spaces with in the plat lying parallel with and adjoining all street(s) in which to construct, operate, maintain, repair, replace and enlarge underground or ground-mounted appurtenances thereto for the purpose of serving this subdivision and other property with electric, gas, telephone and other utility service, together with the right to enter upon the streets, lots, tracts and spaces at all times for the purposes herein stated.